



Pennsylvania Department of Environmental Protection

Lee Park, Suite 6010  
555 North Lane  
Conshohocken, PA 19428  
June 29, 1998

Southeast Regional Office

610-832-5949  
Fax 610-832-6143

Capt. Richard Frattarelli  
Air National Guard  
111 FW/EM  
1120 Fairchild Street  
Willow Grove ARS, PA 19090-5236



Re: ECP - Storage Tank Program  
Pennsylvania Air National Guard  
Facility ID No. 46-34440  
Motor Pool Area  
Willow Grove Air Reserve Station  
Horsham Township  
Montgomery County

Dear Capt. Frattarelli:


The Department has reviewed the Draft Site Characterization Report, Motor Pool Area, 111<sup>th</sup> Fighter Wing submitted by PEER Consultants, P.C. dated February 1998. This Site Characterization documents the contamination associated with the removal of one 6,000 gallon gasoline and one 6,000 gallon diesel fuel underground storage tanks.

The report recommends continued removal of free product through the use of passive skimmers in MW-02 and MW-03 and additional monitoring of MW-04 and MW-05 at six month intervals for two years. The Department concurs with the recommendations contained in Section 5.2 of the report.



If you have any questions, please feel free to contact me at (610) 832 - 5929.

Sincerely,



Pamela S. Reigh  
Hydrogeologist  
Environmental Cleanup Program

cc: Mr. Day-Lewis  
Mr. Forte  
[REDACTED]  
Mr. Charanjit Gill  
Horsham Township  
Montgomery County Health Department  
Re 30 (psr)