



CERTIFICATE OF ANALYSIS

M.J. Reider Associates, Inc.



Attention: [Redacted]
Reported To: [Redacted]
[Redacted] Park Road
Ambler PA 19002-1122

Date of Report: 02/26/13
Lab ID: 4000-13-0006445

Date Collected: 02/12/13 10:50
Collected By: RXA

Sample Desc: [Redacted] Water Sample @ Laundry Room Sink (Park Rd, Ambler PA)

Date Received: 02/12/13 14:40

	Result	Unit	Rep. Limit	Procedure	Test Date	Test Time	Test Analyst	EPA Recommended Minimum	EPA Recommended Maximum	Pass Fail
BACTERIOLOGY										
MICROBIOLOGY										
Total Coliform Bacteria	Absent	/100ml	1	SM 9223B	02/13	11:00	MEP	N/A	1	PASS
INORGANIC										
TOTAL										
Hardness as CaCO3	209	mg/L	1	EPA 200.7	02/18	10:03	LNA	50	180	FAIL
ORGANIC										
VOLATILES										
1,1,1-Trichloroethane	0.0009	mg/L	.0005	EPA 524.2	02/20	08:13	GXF	N/A	.2	PASS
1,1,2-Trichloroethane	<.0005	mg/L	.0005	EPA 524.2	02/20	08:13	GXF	N/A	.005	PASS
1,1-Dichloroethylene	0.0102	mg/L	.0005	EPA 524.2	02/20	08:13	GXF	N/A	.007	FAIL
1,2,4-Trichlorobenzene	<.0005	mg/L	.0005	EPA 524.2	02/20	08:13	GXF	N/A	.07	PASS
1,2-Dichlorobenzene (o-Dichlorobenzene)	<.0005	mg/L	.0005	EPA 524.2	02/20	08:13	GXF	N/A	.6	PASS
1,2-Dichloroethane	<.0005	mg/L	.0005	EPA 524.2	02/20	08:13	GXF	N/A	.005	PASS
1,2-Dichloropropane	<.0005	mg/L	.0005	EPA 524.2	02/20	08:13	GXF	N/A	.005	PASS
1,4-Dichlorobenzene	<.0005	mg/L	.0005	EPA 524.2	02/20	08:13	GXF	N/A	.075	PASS
Benzene	<.0005	mg/L	.0005	EPA 524.2	02/20	08:13	GXF	N/A	.005	PASS
Carbon Tetrachloride	<.0005	mg/L	.0005	EPA 524.2	02/20	08:13	GXF	N/A	.005	PASS
Chlorobenzene (Monochlorobenzene)	<.0005	mg/L	.0005	EPA 524.2	02/20	08:13	GXF	N/A	.1	PASS
cis-1,2-Dichloroethylene	<.0005	mg/L	.0005	EPA 524.2	02/20	08:13	GXF	N/A	.07	PASS
Ethylbenzene	<.0005	mg/L	.0005	EPA 524.2	02/20	08:13	GXF	N/A	.7	PASS
Methylene Chloride	<.0005	mg/L	.0005	EPA 524.2	02/20	08:13	GXF	N/A	.005	PASS
Styrene	<.0005	mg/L	.0005	EPA 524.2	02/20	08:13	GXF	N/A	.1	PASS
Tetrachloroethylene	0.0260	mg/L	.0005	EPA 524.2	02/20	08:13	GXF	N/A	.005	FAIL
Toluene	<.0005	mg/L	.0005	EPA 524.2	02/20	08:13	GXF	N/A	1	PASS
trans-1,2-Dichloroethylene	<.0005	mg/L	.0005	EPA 524.2	02/20	08:13	GXF	N/A	.1	PASS
Trichloroethylene	<.0005	mg/L	.0005	EPA 524.2	02/20	08:13	GXF	N/A	.005	PASS

Distribution of Reports:

Reviewed and Approved by:

Bradley Griffiths
Account Executive & Marketing

This certificate shall not be reproduced except in full without the written approval of M.J. Reider Associates, Inc.



ENVIRONMENTAL TESTING LABORATORY 107 ANGELICA STREET, READING, PA 19611
PHONE: 610-374-5129 • FAX: 610-374-7234 • www.mjreider.com

NELAP accredited by PA. (PADEP #06-00003) (NYSDOH11630) Visit our website to view our current
NELAC accreditations for various drinking water, wastewater and solid & chemical materials analytes.





CERTIFICATE OF ANALYSIS
M.J. Reider Associates, Inc.



Attention: [REDACTED]
Reported To: [REDACTED]
[REDACTED] Park Road
Ambler PA 19002-1122

Date of Report: 02/26/13
Lab ID: 4000-13-0006445
Date Collected: 02/12/13 10:50
Collected By: RXA
Date Received: 02/12/13 14:40

Sample Desc: [REDACTED] Water Sample @ Laundry Room Sink (Park Rd, Ambler PA)

	Result	Unit	Rep. Limit	Procedure	Test Date	Test Time	Analyst	EPA Recommended		Pass/Fail
								Minimum	Maximum	
Vinyl Chloride	<.0005	mg/L	.0005	EPA 524.2	02/20	08:13	GXF	N/A	.002	PASS
Xylenes (Total)	<.0005	mg/L	.0005	EPA 524.2	02/20	08:13	GXF	N/A	10	PASS

A water softener should be considered for hardness values over 180 mg/L.

Hard water can cause reduced life of plumbing & appliances, problems cleaning & laundering, decreased efficiency of water heaters, and chalky deposits on fixtures and glassware.

This water complies with the PA DEP standard for safe drinking water for coliform bacteria.

Reviewed and Approved by:

Bradley Griffiths
Account Executive & Marketing

Distribution of Reports:

This certificate shall not be reproduced except in full without the written approval of M.J. Reider Associates, Inc.

